

Village of Nakusp

RFP 2024-08 – Hot Springs Heat Pump

Addendum 1 – November 26, 2024

This addendum is issued prior to tender closing time and in accordance with the requirements of the contract documents. It shall be read with and form part of the Contract documents.

The closing date and subsequent timeline has changed.

Closing date: December 6, 2024.

Proposals evaluated: December 13, 2024

Q&A

- 1) Is there three phase power on site?
 - a) No, BC Hydro only provides single phase power to the site.
- 2) What is the quality of the water in the circulation loop post pools?
 - a) It has been through a sand filter before entering the pools, but it is the effluent from the pools.